



# Certificate of Compliance

Certificate: 1210062

Master Contract: 208909

Project: 1244628

Date Issued: October 4, 2001

Issued to: **Plug Power**  
968 Albany-Shaker Rd.  
Latham, NY 12110  
USA

Attention: Mr. Kenneth Krastins

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicator 'US'*



Issued by:

Greg Chirton

Authorized by: Todd Strothers  
Engineering Service Manager

## PRODUCTS

2725-81 POWER GENERATORS – Fuel Cell Power Plants

Model Number	Input	Power	Trade Name: Plug Power
For use with Natural Gas	(Btu/hr)	Output (kW)	
SU1	105,000	5.0	

## APPLICABLE REQUIREMENTS

ANSI Z21.83-1998 *Fuel Cell Power Plants*

CSA U.S. Requirements No. 1.01 for *Residential Fuel Cell Power Generators*

## MARKINGS

All markings and printed instructions are in compliance with the above mentioned requirements. Samples are contained in the main certification report.

The 'US' indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL Standards, for use in the U.S.. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.